



## Certificate of conformity n° A25.150

page 1 of 1

**Apparatus:**

**Interface Protection unit**

- Un: 230/400V – 50Hz
- Auxiliary supply Us: 24-240V a.c and V d.c.
- Protection functions (LV and MV):
  - Undervoltage and Overvoltage
  - Underfrequency and Overfrequency
  - Loss of Mains (LOM)

**Designation:**

**PMVF61 (Firmware WM300A0623 of 18/11/2025)**

**Manufacturer:**

**LOVATO Electric S.p.A.**

Via Don E. Mazza, 12 – 24020 Gorle (BG).

**Applicant:**

**LOVATO Electric S.p.A.**

Via Don E. Mazza, 12 – 24020 Gorle (BG).

**Tested by:**

**Lovato Electric S.p.A.**

Via Don E. Mazza, 12 – 24020 Gorle (BG) - Italia

**TUV Italia S.r.l.**

Via Brandizzo 123 - 10088 Volpiano (TO) - Italia

**Eurotest Laboratori S.r.l.**

Via Marconi, 23 - 35020 Brugine (PD) - Italia



### **Standards for distributed renewable resources generators connected to the distribution network**

VERSION 3.0, DECEMBER 2023 SHAMS DUBAI

The test results are shown in the attached ACAE document RIV3263 issued on 5/12/2025.

The values obtained are considered to confirm that the product PMVF61 complies with the above reference document (LV and MV) and justify the characteristics assigned by the manufacturer

ACAE is accredited by



ACAE is member of



The General Secretary  
Date: 2025-12-15