

IEC

IECEE



Ref. Certif. No.

CN71949

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

CONTACTORS FOR CAPACITOR SWITCHING

Name and address of the applicant

Lovato Electric S.P.A.
Via Don E. Mazza,12 24020 Gorle (Bergamo) –Italy

Name and address of the manufacturer

Lovato Electric S.P.A.
Via Don E. Mazza,12 24020 Gorle (Bergamo) –Italy

Name and address of the factory

Lovato Electric S.P.A.
Via Don E. Mazza,12 24020 Gorle (Bergamo) Italy

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Ui: 690V; Uimp: 6kV; Ue: 240V, 400V, 440V, 690V;Ith: 12A(BFK09),
18A(BFK12), 23A(BFK18); Qe: BFK09: 240V/4.5kvar,
400V/7.5kvar,440V/9kvar, 690V/10kvar;BFK12: 240V/7kvar,
400V/12.5kvar, 440V/14kvar, 690V/16kvar; BFK18: 240V/9kvar,
400V/15kvar, 440V/17kvar, 690V/20kvar;AC-6b;Us: AC24V, 110V,
230V, 400V 50/60Hz;3P; Auxiliary contacts (body):1NO, 1NC;Ith:
10A;AC-15: Ue/Ie: 400V/1.9A

Trademark (if any)

lovato

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

BFK09, BFK12, BFK18;

Additional information (if necessary may also be
reported on page 2)A sample of the product was tested and found
to be in conformity with

IEC 60947-1:2020;IEC 60947-4-1:2023

As shown in the Test Report Ref. No. which
forms part of this Certificate

00901-CB2024CQC-116536

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: May.29,2025

Signature:

谢肇煦

Xie ZhaoXu

