

**IEC****IECEE**

®

TM

Ref. Certif. No.

CN76603

**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME****CB TEST CERTIFICATE**

Product

time relay

Name and address of the applicant

Lovato Electric S.P.A.  
Via Don E. Mazza,12 24020 Gorle (Bergamo) –Italy

Name and address of the manufacturer

Lovato Electric S.P.A.  
Via Don E. Mazza,12 24020 Gorle (Bergamo) –Italy

Name and address of the factory

Lovato Electric S.P.A.  
Via Don E. Mazza,12 24020 Gorle (Bergamo) –Italy*Note: When more than one factory, please report on page 2*

Ratings and principal characteristics

Ui: 250V; Uimp: 4kV; Ith: 8A (TMP, TMPA440, TMM1NFC, TMST, TMSTA440), 5A (TMD), 16A (TMRTC, TMAST); AC-15: Ue/Ie: 250V/8A; Us: TMST/TMP: 24-48VDC/24-240VAC; TMSTA440/TMPA440: 380-440VAC; TMD: 24-240VDC/AC; TMM1NFC: 12-240VDC/AC; IP20

Trademark (if any)

Lovato

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

TM

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 60947-5-1:2024 to be used in conjunction with IEC 60947-1:2020

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2025CQC-125062

**This CB Test Certificate is issued by the National Certification Body****CHINA QUALITY CERTIFICATION CENTRE CO., LTD.**Section 9, No. 188, Nansihuan Xilu, Fengtai District, Beijing 100070 P. R. China  
Tel: +86-10-83886666 Fax: +86-10-83886282  
website: <http://www.cqc.com.cn>

Date: Apr.23,2026

Signature:

Liu Jiang