



Certificate of conformity n° A 26.028

page 1 of 1

This Certificate applies only to the apparatus verified. The responsibility for conformity of any apparatus having the same designation with that verified rests with the manufacturer.

Only integral reproduction of this Certificate or reproductions of this page accompanied by any page(s) on which are stated the verifications performed and the assigned rated characteristics of the apparatus verified, are permitted without written permission from the ACAE.



Apparatus:

Interface Protection unit

- Un: 240/415V – 50Hz
- Auxiliary supply Us: 24-240V a.c and V d.c.
- Protection functions (LV):
 - o Undervoltage and Overvoltage
 - o Underfrequency and Overfrequency
 - o Loss of Mains (LOM)

Designation:

PMVF61 (Firmware WM300A0623 of 18/11/2025)

Manufacturer:

LOVATO Electric S.p.A.
Via Don E. Mazza, 12 – 24020 Gorle (BG).

Applicant:

LOVATO Electric S.p.A.
Via Don E. Mazza, 12 – 24020 Gorle (BG).

Tested by:

Lovato Electric S.p.A.
Via Don E. Mazza, 12 24020 Gorle (BG) - Italia

Standards:

EP-EPP-P7-S1 (KAHRAMAA Qatar)
Technical specification for the connection of PV system to the network

The test results are shown in the attached ACAE document RIV 3311 issued on 11/05/2026.

The values obtained are considered to confirm that the product PMVF61 complies with the above reference document and justify the characteristics assigned by the manufacturer

ACAE is accredited by



ACAE is member of



The General Secretary
Date: 2026-05-12