



Ref. Certif. No.

IT-ACAE-0009 pag.1 of 1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Contactors

Name and address of the applicant

Lovato Electric S.p.A.
Via don E. Mazza, 12 – 24020 – Gorle (BG)

Name and address of the manufacturer

Lovato Electric S.p.A.
Via don E. Mazza, 12 – 24020 – Gorle (BG)

Name and address of the factory

Lovato Electric S.p.A.
Via don E. Mazza, 12 – 24020 – Gorle (BG)

Note: When more than one factory, please report on page 2

Additional Information on page 2

Ratings and principal characteristics

Electrical ratings: Ui: 690V; Uimp: 6kV;
Ith: 25A (BF09), 28A (BF12), 32A (BF18, BF25)
AC-3 - Ue/Ie:
BF09:AC230V/400V/9A, AC500V/690V/9A;
BF12:AC230V/400V/12A, AC500V/690V/12A;
BF18:AC230V/400V/18A, AC500V/690V/12A;
BF25:AC230V/400V/25A, AC500V/690V/12.8A

Trademark / Brand (if any)

Lovato Electric

Customer's Testing Facility (CTF) Stage used

CTF stage 2

Model / Type Ref.

BF09, BF12, BF18, BF25

Additional information (if necessary may also be reported on page

Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60947-4-1: 2023

As shown in the Test Report Ref. No. which forms part of this Certificate

3093

This CB Test Certificate is issued by the National Certification Body



ACAE

Via Tito Livio, 5 – 24123 – BERGAMO (Italy)
Tel. +39 035 417 5244 Website: <http://www.acaecert.it>

Date: Mar.27,2026

Signature: G. Cassinelli