



Product Service

CERTIFICATE

No. B 084111 0066 Rev. 00

Holder of Certificate: **LOVATO ELECTRIC S.p.A.**



Via Don Emilio Mazza 12
24020 Gorle (BG)
ITALY

Certification Mark:



Product:

**Switches for household and similar fixed el.
installations
Miniature Circuit-breaker**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the Testing, Certification, Validation and Verification Regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 701282601236-00

Valid until: 2030-12-15

Date, 2026-04-09

(Jie Zhu)

CERTIFICATE

No. B 084111 0066 Rev. 00

Model(s): P1 MB 1M

Brand Name: Lovato

Parameters:

Rated impulse withstand voltage:	4kV
Rated insulation voltage:	500V
Rated operational voltage:	AC230/240V
Rated frequency:	50/60Hz
Rated current:	2A, 4A, 6A, 10A, 16A, 20A, 25A, 32A, 40A
Instantaneous tripping current:	Type B, C, D
Short-circuit capacity:	Ics=Icn= 6000A
Number of poles:	2P (1 protected pole with a switched neutral pole)
Degree of protection:	IP20 (after mounting)

Tested according to: EN 60898-1:2019