KBB2L03



LIMIT SWITCH, K SERIES, TOP ROLLER PUSH PLUNGER, 1 BOTTOM CABLE ENTRY. DIMENSIONS TO EN 50047, PLASTIC BODY, CONTACTS 3NC SLOW ACTION. METAL ROLLER



Product designation	Top roller push plunger
Product type designation	KBB
General characteristics	
Material	

		Housing		Polymer
		Roller		thermoplastic Metal
Contact characteristics		Kollei		Mela
Type of contact				3NC Slow action
Thermal current Ith			Α	10
IEC/EN 60947-5-1 designation				A600 Q600
Rated insulation voltage Ui			V	690
Rated impulse withstand voltage	e Uimp		kV	6
Insulation class	ł			
Short-circuit protection with fus	e		Class/A	10 gG/SC QUICK FUSE
Switching speed				
		min	m/s	0.5
		max	m/s	1.5
IEC Conventional free air therm	nal current Ith		А	10
Resistance per pole (average v	value)		mΩ	<10
Mechanical features				
Operating head fixing				Locking bayonet insert
Operating torque				
			Ν	5
			lb	1.1
Tightening torque (Max)				
Switch	fixing			
			Nm	2.5
			lbin	22.1
Contac	t terminals			
			Nm	0.8
Deduil	d o orow fiving		lbin	7
Body ii	d screw fixing		Nm	0.8
			lbin	7
Conductor section				
AWG/ł	Comil			
,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,		min		16
		max		14
IEC				
		min	mm²	1or 2
		max	mm²	2.5

KBB2L03




LIMIT SWITCH, K SERIES, TOP ROLLER PUSH PLUNGER, 1 BOTTOM CABLE ENTRY. DIMENSIONS TO EN 50047, PLASTIC BODY, CONTACTS 3NC SLOW ACTION. METAL ROLLER

KBB2L03

Cable connection				Self-releasing screw terminal
Cable entry				M20 on the bottom
Operations				
Mechanical life			cycles	<1000000
Mechanical operation			cycles/h	3600
Ambient conditions				
Temperature				
	Operating temperature			
		min	°C	-25
		max	°C	+70
	Storage temperature			
		min	°C	-40
		max	°C	+70
Resistance & Protectior	1			
IP degree				
		Terminals		IP20
		Body housing		IP65
Pollution degree				3






Wiring diagrams



LIMIT SWITCH, K SERIES, TOP ROLLER PUSH PLUNGER, 1 BOTTOM CABLE ENTRY. DIMENSIONS TO EN 50047, PLASTIC BODY, CONTACTS 3NC SLOW ACTION. METAL ROLLER

Slow action



3NC

Certifications and compliance

Compliance

Compliance		
	CSA C22.2 n° 14	
	EN 50047	
	IEC/EN 60204-1	
	IEC/EN 60947-1	
	IEC/EN 60947-5-1	
	UL508	
Certificates		
	CCC	
	cULus	
	EAC	
ETIM classification	h	
		EC000030 - End

ETIM 8.0

EC000030 - End switch

KBB2L03