

# LIMIT SWITCH, K SERIES, WOBBLE STICK, OMNIDIRECTIONAL, 1 BOTTOM CABLE ENTRY. DIMENSIONS TO EN 50047, PLASTIC BODY, CONTACTS 1NO+2NC SLOW ACTION. FLEXIBLE ROD



Product designation

Wobble stick, omnidirectional

KBM

## Product type designation General characteristics


Material			
	Housing		Polymer
	_		thermoplastic
	Rod		Flexible
Contact characteristics			4110 0110 01
Type of contact			1NO+2NC Slow action
Thermal current Ith		Α	10
IEC/EN 60947-5-1 designation			A600 Q600
Rated insulation voltage Ui		V	690
Rated impulse withstand voltage Uimp		kV	6
Insulation class			11
Short-circuit protection with fuse		Class/A	10 gG/SC QUICK FUSE
Switching speed			
	min	m/s	0.5
	max	m/s	1.5
IEC Conventional free air thermal current Ith		Α	10
Resistance per pole (average value)		mΩ	<10
Mechanical features			
Operating head fixing			Locking bayonet insert
Operating torque			
		Ncm	1
		ozin	1.42
Tightening torque (Max)			
Switch fixing			
		Nm	2.5
		lbin	22.1
Contact terminals			
		Nm	0.8
		lbin	7
Body lid screw fixing			
		Nm	0.8
		lbin	7
Conductor section			
AWG/Kcmil			
	min		16
	max		14
IEC			
	min	mm²	1or 2
	max	mm²	2.5



**ENERGY AND AUTOMATION** 

LIMIT SWITCH, K SERIES, WOBBLE STICK, OMNIDIRECTIONAL, 1 BOTTOM CABLE ENTRY. DIMENSIONS TO EN 50047, PLASTIC BODY, CONTACTS 1NO+2NC SLOW ACTION. FLEXIBLE ROD

Cable connection				Self-releasing
				screw terminal
Cable entry				M20 on the
Oabic Citry				bottom
Operations				
Mechanical life			cycles	<10000000
Mechanical operation			cycles/h	3600
Ambient conditions				
Temperature				
	Operating temperature			
		min	°C	-25
		max	°C	+70
	Storage temperature			
		min	°C	-40
		max	°C	+70
Resistance & Protect	ion			
IP degree				
-		Terminals		IP20
		Body housing		IP65
Pollution degree		, ,		3
Dimensions				




Wiring diagrams

**ENERGY AND AUTOMATION** 

LIMIT SWITCH, K SERIES, WOBBLE STICK, OMNIDIRECTIONAL, 1 BOTTOM CABLE ENTRY.
DIMENSIONS TO EN 50047, PLASTIC BODY, CONTACTS 1NO+2NC SLOW ACTION.
FLEXIBLE ROD

# Slow action



#### Certifications and compliance

ce

CSA C22.2 n° 14

EN 50047

IEC/EN 60204-1

IEC/EN 60947-1

IEC/EN 60947-5-1

UL508

Certificates

CCC

cULus

EAC

### ETIM classification

**ETIM 8.0** 

EC000030 - End switch