



MOTOR PROTECTION RELAY, NON PHASE FAILURE/NON SINGLE-PHASE SENSITIVE. THREE-POLE (THREE-PHASE), MANUAL RESETTING. DIRECT MOUNTING ON BG06, BG09, BG12 MINI-CONTACTORS, 0.2...0.33A



Product designation			11RFN9
Product type designation			Motor protection
General characteristics			relay
Number of poles		Nr.	3
Overvoltage category			III
Pollution degree			3
Frontal IP degree			IP20
Type of release			Thermal
Protection fuse			memai
1 Totection Tuse	gG (IEC)	۸	1
		A A	0.5
	aM (IEC)	A	0.5 1
Dhana failinn data stinn	RK5 (UL)	A	
Phase failure detection			yes
Reset mode			Manual
Power circuit characteristics			
Rated insulation voltage Ui IEC/EN		V	690
Rated impulse withstand voltage Uimp		kV	8
Rated operational voltage		V	690
Operational frequency			
	min	Hz	0
	max	Hz	400
Operational current le			
	Operational current min	Α	0.2
	The state of the s	Α	0.33
Tripping class	Operational current max	Α	
Tripping class Test Button	The state of the s	A	10A
Test Button	The state of the s	A	10A Yes
Test Button Trip indicator	The state of the s	A	10A
Test Button	The state of the s	A	10A Yes yes
Test Button Trip indicator	The state of the s	A	10A Yes yes
Test Button Trip indicator	Operational current max type	A	10A Yes yes screw and washer
Test Button Trip indicator	Operational current max  type screw		10A Yes yes screw and washer M4
Test Button Trip indicator	Operational current max  type screw width	Mm	10A Yes yes screw and washer M4 9.8
Test Button Trip indicator Terminals	Operational current max  type screw		10A Yes yes screw and washer M4
Test Button Trip indicator	Operational current max  type screw width tool	mm	10A Yes yes screw and washer M4 9.8 Phillips 2
Test Button Trip indicator Terminals	Operational current max  type screw width tool min	mm	10A Yes yes screw and washer M4 9.8 Phillips 2
Test Button Trip indicator Terminals	Operational current max  type screw width tool min max	mm Nm Nm	10A Yes yes screw and washer M4 9.8 Phillips 2 2.3 2.3
Test Button Trip indicator Terminals	Operational current max  type screw width tool  min max min	mm Nm Nm Ibin	10A Yes yes screw and washer M4 9.8 Phillips 2 2.3 2.3 1.7
Test Button Trip indicator Terminals  Tightening torque for terminals	Operational current max  type screw width tool min max	mm Nm Nm	10A Yes yes screw and washer M4 9.8 Phillips 2 2.3 2.3
Test Button Trip indicator Terminals	type screw width tool min max min max min max	mm Nm Nm Ibin	10A Yes yes  screw and washer M4 9.8 Phillips 2  2.3 2.3 1.7 1.7
Test Button Trip indicator Terminals  Tightening torque for terminals  Conductor section	Operational current max  type screw width tool  min max min	mm Nm Nm Ibin	10A Yes yes screw and washer M4 9.8 Phillips 2 2.3 2.3 1.7
Test Button Trip indicator Terminals  Tightening torque for terminals  Conductor section  Auxiliary circuit characteristics	type screw width tool min max min max min max	mm Nm Nm Ibin	10A Yes yes  screw and washer M4 9.8 Phillips 2  2.3 2.3 1.7 1.7
Test Button Trip indicator Terminals  Tightening torque for terminals  Conductor section	type screw width tool min max min max AWG/kcmil max	mm Nm Nm Ibin Ibin	10A Yes yes  screw and washer M4 9.8 Phillips 2  2.3 2.3 1.7 1.7
Test Button Trip indicator Terminals  Tightening torque for terminals  Conductor section  Auxiliary circuit characteristics	type screw width tool min max min max AWG/kcmil max	mm Nm Ibin Ibin	10A Yes yes  screw and washer M4 9.8 Phillips 2  2.3 2.3 1.7 1.7
Test Button Trip indicator Terminals  Tightening torque for terminals  Conductor section  Auxiliary circuit characteristics	type screw width tool min max min max AWG/kcmil max	mm Nm Nm Ibin Ibin	10A Yes yes  screw and washer M4 9.8 Phillips 2  2.3 2.3 1.7 1.7





**ENERGY AND AUTOMATION** 

MOTOR PROTECTION RELAY, NON PHASE FAILURE/NON SINGLE-PHASE SENSITIVE. THREE-POLE (THREE-PHASE), MANUAL RESETTING. DIRECT MOUNTING ON BG06, BG09, BG12 MINI-CONTACTORS, 0.2...0.33A


Auxiliary Rated insulation voltage Ui IEC/EN		V	690
Auxiliary Rated impulse withstand voltage Uimp		kV	6
Auxiliary Rated operational voltage		V	690
Operating current AC15			
	24V	Α	3
	120V	Α	3
	240V	Α	1.5
	380V	Α	0.95
	480V	Α	0.75
	500V	Α	0.72
	600V	Α	0.6
Operating current DC13			
	125V	Α	0.11
	600V	Α	0.22
IEC Conventional free air thermal current Ith		Α	10
Terminals			
	Auxiliary circuit type		screw and
	•		washer
	Auxiliary circuit screw		M3,5
	Auxiliary circuit width	mm	8
One I strength a	Auxiliary circuit tool		Phillips 1
Conductor section	A <del> </del>	2	0.5
	Auxiliary circuit Flexible w/o lug max	mm²	2.5
Timbania a tanana fantamain ala	Auxiliary circut Flexible c/w lug max	mm²	2.5
Tightening torque for terminals	A !! i i	Nima	4
	Auxiliary circuit min	Nm	1
	Auxiliary circuit max	Nm	1
	Auxiliary circuit min Auxiliary circuit max	lbin Ibin	0.74 0.74
UL/CSA and IEC/EN 60947-5-1 designation	Auxiliary Circuit max	IDIII	B600-P600
Ambient conditions			D000-F 000
Operating temperature			
operating temperature	min	°C	-20
	max	°C	55
Storage temperature	max		
Ctorago tomporataro	min	°C	-55
	max	°C	70
Compensation temperature		<u>_</u>	
	min	°C	-15
	max	°C	55
Max altitude		m	3000
Mechanical features			
Operating position			
,	normal		Vertical plan
	allowable		±30°
	12.2		Direct mounting
Fixing			on BG06
			BG09 BG12
Weight		g	123
UL technical data			
Full-load current (FLA) for three-phase AC motor			
	at 480V	Α	0.33
	at 600V	Α	0.33
Dimensions			






**ENERGY AND AUTOMATION** 

MOTOR PROTECTION RELAY, NON PHASE FAILURE/NON SINGLE-PHASE SENSITIVE. THREE-POLE (THREE-PHASE), MANUAL RESETTING. DIRECT MOUNTING ON BG06, BG09, BG12 MINI-CONTACTORS, 0.2...0.33A



## Wiring diagrams



## Certifications and compliance

Compliance

CSA C22.2 n° 14

IEC/EN 60947-1

IEC/EN 60947-4-1

**UL508** 

Certifications

CCC

CSA

cULus

EAC

## ETIM classification

ETIM 8.0

EC000106 -Thermal overload relay

. . . . . ,